

CERTIFICATE

of Conformity of the Factory Production Control

1922 - CPR - 0386

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Products and systems for the protection and repair of concrete structures. Surface protection systems for concrete. Reinforcement corrosion protection

(For list of products, see Annex 1 to 1922 - CPR - 0386 that is an inseparable part of this certificate)

placed on the market under the name or trade mark of

NEOTEX SA

V.Moira Str. 19600 Industrial Area Mandra, Greece

and produced in the manufacturing plant

NEOTEX SA

V. Moira Str. 19600 Industrial Area Mandra, Greece

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards


EN 1504-2:2004 and EN 1504-7:2006

under system 2+ are applied and that the factory production control is assessed to be in conformity with the applicable requirements.

This certificate was first issued on 21.11.2014 and will remain valid until 20.11.2019 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified factory production control certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Issued:
Burgas, 06 December 2018



Manager:


arch. Galina Vasileva



ANNEX I TO CERTIFICATE OF CONFORMITY OF THE FACTORY PRODUCTION CONTROL 1922-CPR-0386 / 06.12.2018

List of Surface protection systems for concrete, acc. to EN 1504-2

No:	Product	Essential characteristics			
		Determination of liquid water permeability (EN 1062-3)	Measurement of bond strength by pull-off (EN 1542)	Determination of carbon dioxide permeability (EN 1062 6)	Determination of water-vapour transmission properties (EN ISO 7783)
1.	Neorooft	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class I
2.	Revinex Flex 2006	< 0.1 kg/m ² h ^{0.5}	≥ 1.0 N/mm ²	>50 m	class I
3.	Neoproof PU W	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class I
4.	Revinex Flex FP	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class I
5.	Revinex Flex ES	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class I
6.	Revinex Flex U360	< 0.1 kg/m ² h ^{0.5}	≥ 1.0 N/mm ²	>50 m	class I
7.	Silatex Super	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class I
8.	Neolastik 1K	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class II
9.	Neoproof Polyurea C1	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class II
10.	Neoproof Polyurea	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class II
11.	Neoproof Polyurea R	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class II
12.	Neopox Special	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class II
13.	Neoproof PU360	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class I
14.	Revinex Roof	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class I
15.	Neodur Fast Track	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class II
16.	Revinex Elastic	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class I
17.	Neoproof PU W-40	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class I
18.	Neodur FT Elastic	< 0.1 kg/m ² h ^{0.5}	≥ 1.5 N/mm ²	>50 m	class II

List of Reinforcement corrosion protection, acc. to EN 1504-7

No:	Product	Essential characteristics		
		Corrosion protection test (EN 15183)	Shear adhesion of coated steel to concrete (pull-out test) (EN 15184)	Determination of glass transition temperatures of polymers (EN 12614)
1.	Ferrorep	pass	pass	>40°C



Issued:
Burgas, 06 December 2018



Manager:



Dedal
Attestation & Certification

arch. Galina Vasileva